



TAMILNADU FIRE - RESCUE SERVICE DEPARTMENT

NO OBJECTION CERTIFICATE

LICENSE No. : 508 / V / RDH / 2023

Date: 14.09.2023

Sub : Fire and Rescue Service - Fire and Rescue Station Redhills – Issuing of No Objection Certificate – Functioning the School

Ref : 1. G.O/ M.s 122 Dt : 14-09-2004/ Dept. of School Education, Tamil Nadu.

2. G.O/ M.s 123 Dt : 14-09-2004/ Dept. of School Education, Tamil Nadu.

3. Date of Requisition letter from R.Krishnamoorthy, 11.09.2023

Based on the Govt. order mentioned above and the requisition letter given by R.KRISHNAMOORTHY at S.No. 51/4, 54/2A, 76/1, 76/3, 77/1A,77/2, 78/1 & 78/2 ANGADU VILLAGE, SHOLAVARAM PANCHAYAT UNION, PONNERI TALUK, THIRUVALLUR DISTRICT, CHENNAI – 600067. The building and premises comprises of (G+3 Floor) Total area 15,143.41Sq.mtrs., Buildup area now construct Ground floor 2238.61 Sq.mtrs only, Total Buildup area 8925.67 Sq.mtrs as per the plan copy owned/occupied KRISH INTERNATIONAL SCHOOL (CBSE) have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 13.09.2023 in the presence of Principal and that the school is granted NOC for a period of one year from 14.09.2023 to 13.09.2024 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE & RESCUE STATION REDHILLS, K.SEENIVASAGAN ON 13.09.2023 .

Official Seal



STATION OFFICER
FIRE & RESCUE STATION REDHILLS,
CHENNAI – 600 052.

CONDITIONS

1. This License is valid for One year from the date of issue.
2. Fire safety systems should be maintained in Good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a. Building occupancy capacity should not be more than 4 people per sq. Meter as per national Building code-2005.
 - b. The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c. As per Para 6.3 of the BIS standards IS 14435 : 1997 if the classrooms have only one entrance, the capacity of the classrooms shall have to be limited to 45 students.
 - d. Periodical maintenance and care should be taken to maintain all fire protection equipment's.
 - e. Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Sub – Urban District at Ambattur.



STATION OFFICER

FIRE & RESCUE STATION REDHILLS,
CHENNAI – 600 052.

To

R.KRISHNAMOORTHY,
KRISH INTERNATIONAL SCHOOL (CBSE),
S.No. 51/4, 54/2A, 76/1, 76/3, 77/1A, 77/2, 78/1 & 78/2,
ANGADU VILLAGE,
SHOLAVARAM PANCHAYAT UNION,
PONNERI TALUK, THIRUVALLUR DISTRICT,
CHENNAI – 600067.

