

The Manager,
SRI KRISH INTERNATIONAL SCHOOL (CBSE)
NO. 1/12, BAJANAI KOVIL STREET,, ANGADU, REDHILLS, CHENNAI - 600 067
TAMILNADU ,THIRUVALLUR , 600067
(M: 9840087875)

SUBJECT: -FRESH AFFILIATION UP TO SENIOR SECONDARY LEVEL-regarding.

Ref : Application No.: - SS-90872-2324 Dated:25/01/2023

Sir/Madam,

This is with reference to school application on the subject cited above. I am directed to convey approval of the Board for Fresh Affiliation up to Senior Secondary Level as per details given below :

Affiliation No used as User ID for both OASIS and LOC/Registration System	1931514
School No	56601
Password for OASIS and LOC/Registration Systems is same as that used for Affiliation Application.	
Affiliated for	Senior Secondary School Examination Class 1 to 12
Category	Fresh Affiliation
Period of affiliation	01.04.2023 to 31.03.2028
Year and Month From which admission can be taken in Class-IX/XI	1 April,2023
Year and Month in which first batch of Class-X/XII will appear in board examinations	1 April,2025

Sl. No.	The school is directed to ensure that :
1	The total number of section of the school shall be restricted to 20 and further increase of section shall be subject to specific approval of the Board on the basis of the request of the school as per affiliation bye laws and subject to the availability of room size of greater than 500 sq ft.
2	The school has not provided proper facilities for CWSN in the school.The regular cubicles have been marked as CWSN toilets, only by putting a signage.They are too small for a wheelchair/walker to navigate.The CWSN toilet for girls is the smallest and most inappropriate cubicle.No infrastructural features of CWSN toilets are seen inside.No such toilets are seen on the upper floors. The school shall construct separate toilets for CWSN, boys and girls on every floor with proper permanent signage indicating the floor number, as per norms of RPwD Act and guidelines issued by the Board within 3 months and submit compliance on SARAS portal.
3	The school has ramps at the main entrance but they dont have a hand rail.Two other entrances in the side wings of the building are seen, without any ramps. The school shall affix hand rail along the ramp at the main entrance and construct ramps at the entrances of the side wings, as per norms of RPwD Act and guidelines issued by the Board within 3 months and submit compliance on SARAS portal.